

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: December 1- 31, 2016

Pollutant and Nitrogen concentrations (reported results may be averages) on 100% dry weight basis.

	As (mg/kg)	Cd (mg/kg)	Cu (mg/kg)	Pb (mg/kg)	Hg (mg/kg)	Mo (mg/kg)	Ni (mg/kg)	Se (mg/kg)	Zn (mg/kg)	Org-N (mg/kg)	Ammonia (mg/kg)	Cr (mg/kg)	% solids
Result Plant 1	7.7	4.2	420	<12	1.0	14	27	5.4	610	55,000	6,500	35	17
Result Plant 2	6.3	5.2	490	13	0.82	15	27	3.8	760	41,000	7,800	40	21
Table 3	41	39	1,500	300	17	N/A	420	100	2,800	N/A	N/A	N/A	N/A
Table 1	75	85	4,300	840	57	75	420	100	7,500	N/A	N/A	3,000	N/A

Class B Pathogen Reduction

Class B pathogen reduction requirements from 40 CFR part 503 and Arizona Administrative Code R18-9-1006 (E) have been met via anaerobic digestion under the following parameters:

	Mean Re Time (Mean minimum Temperature (°F)
	Min	Max	(All digesters)
Plant 1	17	19	98 - 99
Plant 2	20	22	96 - 101

Vector Attraction Reduction

The vector attraction reduction requirements of 40 CFR part 503 and Arizona Administrative Code R18-9-1010(A) have been met using data (may be averages) analyzed by an Arizona certified laboratory to comply with Option 1.

	% Volatile Solids										
	In	Out	Reduction								
Plant 1	3.0	1.2	60								
Plant 2	3.5	1.4	62								

1/24/2017

Certifications:

NPDES permit: I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

503 Class B: I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

Arizona Class B: I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.

1/24/2017

James Spears jspears@ocsd.com Operations Manager (714) 593-7081 Signed by: Spears, Jim

Jomes E. Celter

James E. Colston jcolston@ocsd.com Dir. of Environmental Services (714) 593-7450 Signed by: Colston, Jim

1/18/2017

Ronald Cossrcoss@ocsd.comEnviro Lab and OM Manager(714)593-7508Signed by: Coss, Ronald(714)593-7508

Sampling date(s): <u>12/07/2016,12/14/2016,12/21/2016</u>

Biosolids Notice and Necessary Information – Addendum

Individual Digester Mean Cell Residence Times and Minimum Temperatures

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach, CA

Monitoring Period: December 1- 31, 2016

OCSD Plant 1

	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (days)*	17	16	17	17	17**				17**	17**
Minimum Temperature (°F)	99	99	99	99	99				99	98

Shaded box represents Digester is Out of Service.

*MCRT based on a 15-Day Rolling Average.

OCSD Plant 2

	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. I	Dig. J	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T	
Minimum Mean Cell Residence Time (days)*	21	20		20	20		19	21	21		20	20	20	20	20	20	21	
Minimum Temperature (°F)	96	98		97	97		100	101	99		98	98	96	98	98	98	100	

Shaded box represents Digester is Out of Service.

*MCRT based on a 15-Day Rolling Average.

** On 11/3/2016, instrumentation staff discovered a flowmeter calibration error for digesters 11-16 that had occurred when the meter was rescaled on 5/19/2016. As a result, during that period, the reported digestion times were slightly less than actual digestion times. Since recalculation of digestion times would not negatively affect compliance determination, the data will not be corrected and re-reported.