



Biosolids Monthly Compliance Report

Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach,
Monitoring Period: February 1- 28, 2023

This notice and necessary information demonstrates compliance with requirements of the Code of Federal Regulations Title 40 Part 503 and the Arizona Administrative Code Title 18, Chapter 9, Article 10 for land application pollutant concentrations, Class B pathogen reduction via anaerobic digestion (40CFR 503.32(b)(3)(A)(3), AAC R18-9-1006(E)(5)), and vector attraction reduction via volatile solids reduction (40CFR 503.33(b)(1), AAC R18-9-1010(A)(1)).

Sampling date(s): 02/07/23,02/14/23

	Mercury (mg/kg dry)	Arsenic (mg/kg dry)	Cadmium (mg/kg dry)	Chromium (mg/kg dry)	Copper (mg/kg dry)	Lead (mg/kg dry)	Molybdenum (mg/kg dry)	Nickel (mg/kg dry)	Selenium (mg/kg dry)	Zinc (mg/kg dry)	Ammonia Nitrogen (mg/kg dry)	Organic Nitrogen (mg/kg dry)	Total Nitrogen (mg/kg dry)	pH	Total Solids (%)	VSR (%)
Plant 1 Max/Min*	0.87	9.1 DNQ	2.1	35	430	11	14	31	8.7 DNQ	670	9,500	51,000	58,000	8.1	24	66
Plant 1 Avg	0.79	8.1 DNQ	1.9 DNQ	34	410	9.2 DNQ	14	31	8.3 DNQ	670	8,500	49,000	57,000		25	
Plant 2 Max/Min*	0.61	9.5 DNQ	1.5 DNQ	35	310	8.1	17	26	8.1 DNQ	590	10,000	49,000	55,000	8.1	27	73
Plant 2 Avg	0.60	9.5 DNQ	1.5 DNQ	34	310	6.1 DNQ	17	26	7.0 DNQ	590	8,000	45,000	53,000		28	
Table 1 (Max/Min)*	57	75	85	3000	4300	840	75	420	100	7500	N/A	N/A	N/A	6.5	15	38
Table 3 (Avg)	17	41	39	N/A	1500	300	N/A	420	100	2800	N/A	N/A	N/A	N/A	N/A	N/A

OCSD Plant 1	System Summary	Dig. 7	Dig. 8	Dig. 9	Dig. 10	Dig. 11	Dig. 12	Dig. 13	Dig. 14	Dig. 15	Dig. 16
Minimum Mean Cell Residence Time (Min 15 days)**	24	24	24	25	25	24	Out of Service	23	23	25	Out of Service
Minimum Temperature (Min 95 °F)	98	99	99	99	99	99	Out of Service	98	100	98	Out of Service

OCSD Plant 2	System Summary	Dig. C	Dig. D	Dig. E	Dig. F	Dig. G	Dig. H	Dig. I	Dig. J	Dig. L	Dig. M	Dig. N	Dig. O	Dig. P	Dig. Q	Dig. R	Dig. S	Dig. T
Minimum Mean Cell Residence Time (Min 15 days)**	21	Out of Service	Out of Service	21	Out of Service	21	21	Out of Service	Out of Service	21	21	21	23	Out of Service	Out of Service	Out of Service	21	21
Minimum Temperature (Min 95 °F)	96	Out of Service	Out of Service	97	Out of Service	98	96	Out of Service	Out of Service	97	97	96	96	Out of Service	Out of Service	Out of Service	98	97

DNQ (Detected, Not Quantified) represents estimated values above the method detection limit (MDL), but below the reporting limit (RL).

* Maximum values are reported for metals and nitrogen parameters; minimum values are reported for pH, volatile solids reduction (VSR) and total solids. Analysis of pH is conducted to comply with AAC R18-9-1007(A)(1). The limit for total solids applies only if biosolids are sent to a California landfill, per CCR Title 27 Section 20220(c)(3).

** MCRT based on a 15-Day Rolling Average.


Facility Name: Orange County Sanitation District Reclamation Plant #1, Fountain Valley, CA and Treatment Plant #2, Huntington Beach,
Monitoring Period: February 1- 28, 2023

Certifications:

NPDES permit: *I certify, under penalty of law, that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or the persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*


503 Class B: *I certify, under penalty of law, that the Class B pathogen requirements in 503.32(b) and the vector attraction reduction requirement in 503.33(b)(1) have been met. This determination has been made under my direction and supervision in accordance with the system designed to ensure that qualified personnel properly gather and evaluate the information used to determine that the pathogen requirements and vector attraction requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*

Arizona Class B: *I certify, under penalty of law, that the pollutant analyses and the description of pathogen treatment and vector attraction reduction activities have been made under my direction and supervision and under a system designed to ensure that qualified personnel properly gather and evaluate the information used to determine whether the applicable biosolids requirements have been met. I am aware that there are significant penalties for false certification including the possibility of fine and imprisonment.*



Jim Spears
Operations Manager

jspears@ocsan.gov
(714) 593-7081



Lan C. Wiborg
Environmental Services Director

lwiborg@ocsan.gov
(714) 593-7540

 <small>Cindy Vellucci (May 16, 2023 08:33 PDT)</small>				
Cindy Vellucci	Christopher Myrter	Rachel Van Exel	Peter Park	Tom Meregillano